Job Name/Location:					Tag #:
Date:		For:	File	Resubmit	ė,
PO No.:			Approval	Other	
Architect:	GC:				
Engr:	Mech	:			
Rep:					

(Project Manager)

## LMCN078HV

Multi F Ceiling Cassette Indoor Unit 7,000 Btu/h



#### Performance:

(Company)

Nominal Cooling Capacity (Btu/h)	7,000
Nominal Heating Capacity (Btu/h)	8,100

Cooling Nominal Test Conditions: Indoor: 80°F DB / 67°F WB Outdoor: 95°F DB / 75°F WB

Heating Nominal Test Conditions: Indoor: 70°F DB / 60°F WB Outdoor: 47°F DB / 43°F WB

#### Electrical:

Power Supply (V¹/Hz/Ø)	208-230/60/1
Rated Amps (A)	0.25

## Piping:

Installed Liquid Pipe (in., O.D.)	ø1/4
Installed Vapor Pipe (in., O.D.)	ø3/8
Liquid Connection (in., O.D.)	ø1/4
Vapor Connection (in., O.D.)	ø3/8
Drain (in., O.D. / I.D.)	1-1/4, 1
Temperature Sensor	Thermistor

• Group control

module

• Inverter (variable speed fan)

· Compatible with accessory Wi-Fi

#### **Controls Features:**

- Two thermistor control
- 24-Hour on / off timer
- Auto operation
- Auto restart
- Chaos swing
- Control lock function
- Drain pump

# **Entering Mixed Air:**

Cooling (°F WB)	57 ~ 77
Heating (°F DB)	59 ~ 81

#### **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	EEV
Sound Pressure (H/M/L) dB(A) <sup>2</sup>	31 / 27 / 24
Primary Filter <sup>3</sup>	Washable Pre-filter
Net Weight (lbs.)	26
Shipping Weight (lbs.)	31
Grille Net Weight (lbs.)	7
Grille Shipping Weight (lbs.)	9

#### Fan:

Туре	Turbo
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow H/M/L (CFM)	265 / 212 / 177

### **Included Accessories:**

• Wireless Remote Controller — AKB73757604

#### **Required Accessories:**

- $\square$  Grille Kit (27-9/16" x 27-9/16") PT-UQC, or ☐ Grille Kit (24-7/16" x 24-7/16") - PT-QCHW0
- **Optional Accessories:**
- ☐ MultiSITE™ CRC1 Controller PREMTBVC0
- ☐ MultiSITE™ CRC1+ Controller PREMTBVC1
- ☐ Simple Remote Controller PREMTC00U
- ☐ Premium Remote Controller PREMTA000 ☐ Remote Temperature Button Sensor - ZRTBS01
- ☐ Simple Dry Contact (1 contact, 24 VAC external power) PDRYCB100
- ☐ Dry Contact for Third Party Thermostat PDRYCB300
- ☐ Dry Contact for Economizer PDRYCB400
- ☐ Auxiliary Heater Kit PRARH1
- ☐ Wi-Fi Module PWFMDD200

#### Notes:

- NOLES:

  1. Acceptable operating voltage: 187V-253V.

  2. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.

  3. Removable Washable Filter size: 14" x 14" x 1".

  4. See Engineering Manual for sensible and latent capacities.

  5. All communication / connection (power) cable from the outdoor unit to the indoor unit is field supplied and must be a minimum of four-conductor, 18 AWG, stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoor unit only), and must comply with applicable local and national codes.

  6. Power wiring cable size must comply with the applicable local and national code.

  7. The indoor unit comes with a dry helium charge.
- 8. Corresponding refrigerant piping length is in accordance with standard length of each outdoor unit and the level difference is 0 ft. All capacities are net with a combination ratio between 95 105%.

  9. Must follow installation instructions in the applicable LG installation manual.







Job	Name.	/Location:

# LMCN078HV

Multi F Ceiling Cassette Indoor Unit 7,000 Btu/h



Tag No.: Date:

Life's Good PO No.: 4-17/32 2-51/64 (115) (71)

