

PROTECTOR DIESEL PRE-ORDER CHECKLIST

 The local fire marshal has confirmed that the generator must be located a minimum of feet from a house or other structure. NOTE: Generac recommends a minimum clearance of five feet.
□ The local AHJ has advised me regarding the requirements for electrical and/or building permits, as well as those regulations relating to emissions and fuel storage.
□ I have been advised of the local requirements for construction of a concrete base pad, and whether anchoring requirements are needed for installation on a flood plain.
□ I have confirmed with the appropriate authorities that the generator must be located a minimum of feet from a property line.
□ I have been advised whether the local fire marshal (or other third party) is required to be present at start up.
□ I have confirmed that the installation site is applicable to optional standby only and does not require an NFPA 110 capable generator.
□ The local fire marshal has confirmed that I am required to extend the fuel tank vents feet above the surrounding grade.
□ The local fire marshal has confirmed that local codes require installation of the diesel product safety accessories designated below.

ltem	Description	Part Number	Required
	Emergency Stop Switch	006510-0	□ YES □ NO
Aug Br Aug Br Br Br Br Br Br Br Br Br Br Br Br Br	90% Fuel Level Alarm	006504-0	□ YES □ NO

Item	Description	Part Number	Required
	Five Gallon Spill Box	006502-0	□ YES □ NO
	Spill Box Drain Back	006511-0	□ YES □ NO
	Anti-Static Fuel Fill Tube	006507-0	□ YES □ NO
	Fuel Tank Support Risers	006505-0 (15 & 20 kW) 006506-0 (30 & 50 kW)	□ YES □ NO □ YES □ NO
and a second	Stainless Steel Fuel Lines	006513-0 (15 & 20 kW) 006517-0 (30 kW) 006516-0 (50 kW)	□ YES □ NO □ YES □ NO □ YES □ NO