

100 & 200 AMP OWNER'S & INSTALLATION MANUAL MODEL



**California
Proposition 65 Warning**

Certain components in this product and its related accessories contain chemicals known to the state of California to cause cancer, birth defects or other reproductive harm. Wash hands after handling.

DISCLAIMERS:

All information, illustrations and specifications in this manual are based on the latest information available at the time of publishing. The illustrations used in this manual are intended as representative reference views only. Moreover, because of our continuous product improvement policy, we may modify information, illustrations and/or specifications to explain and/or exemplify a product, service or maintenance improvement. We reserve the right to make any change at any time without notice. Some images may vary depending upon which model is shown.

ALL RIGHTS RESERVED:

No part of this publication may be reproduced or used in any form by any means – graphic, electronic or mechanical, including photocopying, recording, taping or information storage and retrieval systems – without the written permission of Milbank Manufacturing.

ORIGINAL INSTRUCTIONS (English):

The English version of this manual controls over any error in or conflicting interpretation of any translation.

TABLE OF CONTENTS

CONTACT INFORMATION	5
CONTACT INFORMATION	5
AUTOMATIC TRANSFER SWITCH (ATS)	5
GENERATOR	5
SAFETY	6
IMPORTANT SAFETY INSTRUCTIONS	6
Safety Symbol Meanings	6
SAFETY LABELS	7
GENERAL SAFETY PRECAUTIONS	7
SPECIFICATIONS.....	8
VIGILANT 100A/200A SPECIFICATIONS	8
VIGILANT PRODUCT SERIES.....	9
VIGILANT PRODUCT OVERVIEW	9
RECEIVING, HANDLING AND STORAGE	9
Receiving	9
Handling	9
Storage	9
VIGILANT CATALOG NUMBER IDENTIFICATION.....	10
INSTALLATION AND WIRING	11
GENERAL INFORMATION	11
MOUNTING LOCATION.....	11
MOUNTING REQUIREMENTS.....	11
RECOMMENDED UPSTREAM PROTECTION.....	11
POWER CONNECTIONS	12
LUG TORQUE VALUES	12
SUITABLE CIRCUIT BREAKERS	13
CONNECTIONS	14
GENERAL OPERATION	15
VIGILANT SERIES GENERAL OPERATION.....	15
ADJUSTMENTS AND SETTINGS.....	16
VIGILANT SERIES ADJUSTMENTS AND SETTINGS	16
System Adjustments	17
Dip Switch Settings	17
Timing Adjustments	18
Testing Adjustments	19
Controller test switch	19
Remote test switch	19
Exerciser	19
MANUAL TRANSFER	20
MANUAL TRANSFER OF MECHANISM	20
100A/200A Manual Transfer	20
MAINTENANCE	21
RECOMMENDED MAINTENANCE	21
MAINTENANCE	21
DRAWINGS.....	22
MGVATS1001240 GENERAL ARRANGEMENT	22
MGVATS2001240 GENERAL ARRANGEMENT	23
MGVATS2001240 GENERAL ARRANGEMENT 2	24
MGVATS1001240/MGVATS2001240 WIRING DIAGRAM	25

TABLE OF CONTENTS

EXERCISER.....26

ENGINE EXERCISER AND EXTERNAL LED ANNUNCIATION26

 Introduction.....26

 Clearing the Exerciser27

 Set Current Time and Date.....27

 Set Program Timing.....27

 Program Review27

 ON/AUTO/OFF Mode27

WARRANTY.....28

MILBANK MANUFACTURING VIGILANT™ OWNER WARRANTY POLICY28

 Limited Warranty.....28

 Warranty Period.....28

 Warranty Registration Process.....28

 About Our Warranty.....29

Thank you for your purchase of a Milbank Vigilant Series Automatic Transfer Switch (ATS). This product is designed for use with standby generators. This ATS may have different installation requirements depending on the generator manufacturer or design. When operated and maintained according to the instructions in this manual, your system will provide many years of standby electrical energy service.

This manual contains important safety instructions for installation and operation of this ATS. We have made every effort to provide safe, efficient instructions for installation and operation. However, as every installation is unique, it is impossible to anticipate every possible procedure and method to obtain a properly installed unit. It is important that you read and understand these instructions thoroughly before attempting to install or operate this unit. Your equipment is supplied with this combined Installation and User Manual. **This is an important document and should be retained by the owner after the installation has been completed.** An electronic version can be downloaded at milbankworks.com.

This ATS requires professional installation before use. Refer to the installation section of this manual for instructions on installation procedures. **Only licensed electrical contractors should install an ATS.** Installations must comply completely with all federal, state and local codes, standards and regulations. Your installer should follow these instructions completely. Every effort has been made to ensure that the information in this manual is both accurate and current. However, the manufacturer reserves the right to change, alter or otherwise improve the system at any time without prior notice.

NOTICE

Please check with the generator manufacturer to ensure the Vigilant switch is compatible.

CONTACT INFORMATION

There are several ways to contact us for answers to questions you may have about your product. Contact Technical Services by phone at (816) 410-7346, Monday through Friday, 8 a.m. to 5 p.m, Central Time. Electronic communication can be made through our website milbankworks.com where you can locate an authorized repair technician, or by email at PGTS@milbankworks.com.

For your future reference, record the following pertinent information. This information will help to identify product information should you need to contact Milbank's Technical Services department.

ATS

Model Number: _____

Description: _____

Serial Number: _____

Installation Date: _____

GENERATOR

Model Number: _____

Description: _____

Serial Number: _____

Installation Date: _____

SAFETY

IMPORTANT SAFETY INSTRUCTIONS



Read Manufacturer's Instructions.
SAVE THESE INSTRUCTIONS.

- This manual contains important information that should be used during installation, maintenance and operation of this unit.
- Read all the instructions and safety symbols thoroughly before attempting to install, operate and/or service this equipment.

Safety Symbol Meanings

Symbol	Description
	Safety Alert Symbol
	Crush Hazard
	Electrical Shock Hazard



This safety alert symbol appears with most safety statements. It means attention, become alert, your safety is involved! Please read and abide by the message that follows the safety alert symbol.



DANGER

Indicates a hazardous situation which, if not avoided, **will** result in death or serious injury.



WARNING

Indicates a hazardous situation which, if not avoided, **could** result in death or serious injury.



CAUTION

Indicates a hazardous situation which, if not avoided, **could** result in minor or moderate injury.

NOTICE

Indicates a situation which can cause damage to the equipment, personal property and/or the environment, or cause the equipment to operate improperly.

NOTE: Indicates a procedure, practice or condition that should be followed in order for the generator to function in the manner intended.

The manufacturer of this product cannot reasonably anticipate every possible circumstance that might involve a hazard. The warnings in this manual and the tags and decals affixed to the unit are, therefore, not all-inclusive. If you use a procedure, work method or operating technique that the manufacturer does not specifically recommend, you must ensure that your method is safe for you and others. You must also make sure that the procedure, work method or operating technique that you choose does not render the equipment unsafe.

SAFETY LABELS



Always replace any illegible or missing labels immediately. All safety labels must be legible to alert personnel to safety hazards.



Figure 1 – Milbank PN 1168019

GENERAL SAFETY PRECAUTIONS

DANGER



DANGER! Equipment contains high voltage. Despite the safe design of the system, operating this equipment imprudently, neglecting its maintenance or being careless can result in death or serious injury.

WARNING



The safety messages that follow have WARNING level hazards.

- Unauthorized or improper installation, operation, application or repair of this equipment is extremely dangerous.
- Only qualified electricians should attempt installation of this equipment, which must strictly comply with all applicable codes, standards and regulations.
- When connecting a generator system to an electrical system that is normally supplied by an electric utility company, always comply with regulations of the National Electrical Code (NEC) (Article 701 Legally Required Standby Systems or Article 702 Optional Standby Systems, as applicable), and Occupational Safety and Health Administration (OSHA), as applicable. It is essential to use the latest version of any standard to ensure all current information is applied.

WARNING



The safety messages that follow have WARNING level hazards.

- Failure to properly ground equipment can result in electrocution.
 - Do not touch bare wires.
 - Do not use equipment with worn, frayed, bare or otherwise damaged wiring.
 - Do not handle electrical cords while standing in water, while barefoot, or while hands or feet are wet.
 - If you must work around a unit while it is operating, stand on an insulated dry surface to reduce shock hazard.
 - Do not allow unqualified persons or children to service equipment.
 - In case of an accident caused by electrical shock, immediately shut down all sources of electrical power and contact local authorities. Avoid direct contact with the victim.
- Low-voltage wire cannot be installed in the same conduit as power voltage wiring.
- Dangerous power voltages are present inside a live ATS. Never work on the ATS unless all power voltage supplies to the switch have been turned off.
- When an ATS is connected to a standby generator, the generator engine may crank and start at any time without notice to the end user. To avoid injury that may be caused by such start-ups, move the safety disconnect switch on the front panel to the OFF position before working on this equipment.

NOTICE

Improper treatment of equipment can damage it and shorten its life.

- Use equipment only for intended uses.
- If you have questions about intended use, ask a Milbank certified technician or contact Milbank Manufacturing's PowerGen™ division.
- Do not expose equipment to excessive moisture, dust, dirt or corrosive vapors.
- Remain alert at all times while working on this equipment. Never work on the equipment when you are physically or mentally fatigued.
- If connected devices overheat, turn them off and turn off their circuit breaker or fuse.

SPECIFICATIONS

VIGILANT 100A/200A SPECIFICATIONS

Vigilant series transfer switches do not support Delta configurations.			
UL1008	Emergency Standby rated		
AC current rating	100/200A, 2-pole		
AC voltage rating	120/240V		
	AC voltage sensing is line to neutral. ¹		
Ambient temperature rating	113°F (45°C) at 100A/200A 131°F (55°C) at 90A/180A 149°F (65°C) at 75A/150A 158°F (70°C) at 70A/140A Do not exceed 158°F (70°C)		
RSC rating	10A maximum		
DC operating voltage	12/24V DC (Voltage Range 9-30V DC)		
DC power consumption	25 mA @ 12V DC		
Control setting ranges	Function	Range	Setting
	Time Delay Engine Start (TDES)	3-32 seconds	13 seconds (1.56V DC @ TP J2-1)
	Time Delay Normal (Utility) to Emergency (Generator) (TDNE)	11-64 seconds	21 seconds (0.78V DC @ TP J2-2)
	Time Delay Emergency (Generator) Transfer to Normal (Utility) (TDEN)	9-256 seconds	256 seconds (5.00V DC @ TP J2-3)
	Time Delay Engine Cooldown (TDEC)	0-256 seconds	256 seconds (5.00V DC @ TP J2-4)
	Time Delay Neutral Position (TDNP) (600A only)	0-64 seconds	10 seconds (0.78V DC @ TP J2-5)
	Normal Line Sensing Under Voltage	Dropout (11-18%) Pickup (6-13%) (±2% accuracy)	Dropout (18%) Pickup (13%) (±2% accuracy)
	Normal Line Sensing Under Frequency	5-12% (±1% accuracy)	12% (±1% accuracy)
	Emergency Line Sensing Under Voltage	Dropout (11-18%) Pickup (6-13%) (±2% accuracy)	Dropout (18%) Pickup (13%) (±2% accuracy)
Over/under voltage sensing*	Dropout (11-18%) Pickup (6-13%) adjustable Percentage above or below normal voltage to recognize an unacceptable voltage condition (±2% accuracy).		
Over/under frequency sensing	5-12% adjustable Percentage above or below normal frequency to recognize an unacceptable frequency condition (±1% accuracy).		
Exerciser timer	Included		
Test switch	Included		
UL withstand/closing ratings	22,000A with properly rated 100A circuit breaker - 480V (400A) 25,000A with properly rated 200A circuit breaker - 480V (600A)		
Lug capacities	100A – 1/0 to 14 AWG 200A – 1/0 to 250 MCM		
Overall dimensions	100A/Open type – 13 x 12 x 0.5 in. (33.0 x 30.5 x 1.27 cm) - 240 18 x 18 x 0.5 in. (45.7 x 45.7 x 1.27 cm) - 480 100A/Enclosure – 16 x 14 x 06 in. (40 x 35.6 x 15.2 cm) - 240 20 x 20 x 06 in. (50.8 x 50.8 x 15.2 cm) - 480 200A/Open type – 22 x 18 x 0.5 in. (55.9 x 45.7 x 1.27 cm) 200A/Enclosure – 24 x 20 x 06 in. (61.0 x 50.8 x 15.2 cm)		
Weight	100A - 25 lb (11.3 kg), 200A - 51 lb (23.1 kg)		

¹ One of the connected L-N phases must be below the under-voltage threshold to initiate transfer sequence.

VIGILANT PRODUCT OVERVIEW

Milbank Vigilant series automatic transfer switches are represented by the MGVATS product identifier designed with all required sensing circuitry provided. The sensing circuitry allows automatic transfer of an electrical load to a standby power source in the event of an over/under voltage or frequency condition on any or all phases of the utility power source. Upon the restoration of the utility supply, the electrical load will be automatically retransferred to the utility power source.

All Vigilant transfer switch mechanisms incorporate a double-throw action switching device for automatic transferring. The Vigilant transfer switch mechanism is a contactor-operated device controlled by a set of utility and generator solenoids. Manual operation is also provided for manual transfer of the load between the power sources if necessary.



Figure 2 – Vigilant Series

RECEIVING, HANDLING AND STORAGE

Shipment contents:

- Vigilant Series – Automatic Transfer Switch
- Installation and User Manual
- Warranty card

Receiving



Every effort is made to ensure that your Vigilant transfer switch arrives at its destination undamaged and ready for installation. The packing is designed to protect the transfer switch's internal components as well as the enclosure. Care should be taken to protect the equipment from impact at all times. Do not remove the protective packaging until the equipment is at the installation site and ready to be installed.

After unpacking, inspect the switch for any damage that may have occurred during shipping. If any missing parts or damage is discovered when unpacking, do not return the unit to the place of purchase; please contact Milbank Technical Services for instructions on how to proceed. Never install a switch that has been damaged.

A shipping label affixed to the shipping box includes a variety of product and shipping information, such as items and customer numbers. Make certain that this information matches your order information.

Handling



As previously mentioned, each Vigilant transfer switch is packaged in its own individual box. Protect the equipment from impact at all times and do not double stack. Once the transfer switch is at the installation site and ready to be installed, the packaging material may be removed.

Storage



Although well packaged, this equipment is not suitable for outdoor storage. If the transfer switch is to be stored indoors for any period of time, it should be stored with its protective packaging in place. Protect the transfer switch at all times from excessive moisture, dirty conditions, corrosive conditions and other contaminants. It is strongly recommended that the package-protected equipment be stored in a climate-controlled environment of -4° to 149°F (-20° to 65°C), with a relative humidity of 80% or less. Do not stack other equipment on top of the stored switches.

VIGILANT CATALOG NUMBER IDENTIFICATION

MGVATSXXXXXXXXX
VTS2-XXXX
AUTOMATIC TRANSFER SWITCH
XXXXX PHASE 120-XXX VAC 60Hz XXXX AMPS
Type 3R Enclosure
Suitable for use as service equipment.
Suitable for control of motors, electric discharge lamps, tungsten filament lamps and electric heating equipment where the sum of motor full-load amps ratings and amps of other loads do not exceed the amp rating of the switch and tungsten loads do not exceed 30% of the switch rating.
This transfer switch is rated for use on a circuit capable of delivering not more than the symmetrical amps at voltage shown below:

SHORT-CIRCUIT CURRENT (RMS SYMMETRICAL AMPERES X 1000)	VOLTAGE (VOLTS AC, MAXIMUM)
XX	XXX

When protected by a circuit breaker rated as follows:

HED4, HED6	Siemens	125A	240V	100KA
QCHW	CH	125A	240V	22KA
FDC	CH	150A	240V	200KA
ED4, ED6	Siemens	125A	240V	65KA
CED6	Siemens	125A	240V	200KA

See MGVATSXXXXXXXXX manual for installation, configuration, and ATS automatic sequence. Generator control circuits shall be in conduit.

LOAD, UTILITY, GENERATOR, AND NEUTRAL TERMINALS:

	Screw Driver	External Drive Wrench
12 - 10 awg cu/al	35 in-lbs	75 in-lbs
8 awg cu/al	40 in-lbs	110 in-lbs
6 - 4 awg cu/al	45 in-lbs	150 in-lbs
2 - 1/0 awg cu/al	50 in-lbs	180 in-lbs

MILBANK
www.milbankworks.com
GENERAL OFFICES, K.C. MO
MADE IN U.S.A. PLANT 4

Serial Number:
GN0XXXX0013H20203544



1167854
REV. *1

Figure 3 – Milbank PN 1167854

10

Milbank Vigilant™ Owner's and Installation Manual

INSTALLATION AND WIRING

GENERAL INFORMATION

All Vigilant transfer switches are factory-tested and approved. Installation requires the mounting of the transfer switch as well as all external wiring for utility and generator operation. Once the transfer switch is properly installed, it should be visually inspected and approved before any testing is performed.

MOUNTING LOCATION

IMPORTANT: Vigilant series transfer switches do not support Delta configurations.



WARNING



Always use adequate lifting to lift and mount the transfer switch during installation.

All Vigilant transfer switches require that adequate lifting means are used to install the switch at its mounting location. Be certain to choose a location that offers a flat mounting surface that is capable of supporting the transfer switch (see *Vigilant 100A/200A Specifications on page 8* for proper weight details). Caution must be taken at the installation site to make sure the site is free from excessive moisture, fluctuating temperature ranges, dust, corrosive materials, etc. Before any drilling takes place, be certain the drilling area is free of any hazards including electrical wiring, piping, etc. Extreme caution should be exercised when any installation and drilling are performed to protect the transfer switch from any debris including contaminants, filings, etc. Any debris within the transfer switch may result in a system malfunction.

MOUNTING REQUIREMENTS

The enclosure has a NEMA (National Electrical Manufacturer's Association) type 3R rating and is suitable for indoor/outdoor installations and provides a degree of protection against falling rain and sleet. Guidelines for mounting the unit include:

- Ensure that the mounting surface can support the weight of the switch and adheres to all local codes.
- The enclosure must be installed with NEMA type 3R hardware and connections.
- Level and plumb the unit enclosure to prevent deformation.
- Never install the switch where any corrosive substance may come in contact with the enclosure.
- Protect the switch at all times against excessive moisture, dust, dirt, lint, construction grit and corrosive vapors.

RECOMMENDED UPSTREAM PROTECTION

When protected by a circuit breaker rated at 100A maximum for 100A rated transfer switches, this switch is suitable for use on a circuit capable of delivering not more than 22,000A RMS SYMMETRICAL AT 240V.

When protected by a circuit breaker rated at 200A maximum for 200A rated transfer switches, this switch is suitable for use on a circuit capable of delivering not more than 25,000A RMS SYMMETRICAL AT 240V.

For suitable circuit breakers, see *Table 3* and *Table 4* on page 13.

Use copper or aluminum wiring 60/75C rating for power terminals.



CAUTION

Using upstream protection devices other than the recommended circuit breakers may cause improper operation of the Vigilant switch.



WARNING



Always de-energize power connections before installing any connections. Power lines may carry high voltage. Exercise extreme caution when installing any power connections to the Vigilant switch.

INSTALLATION AND WIRING

POWER CONNECTIONS

Proper power cables need to be installed to the transfer switch and should be installed by licensed electrical contractors. Improper installation or connections of these power cables are extremely dangerous and may cause severe injury or death. All power connections are to be connected to the proper lugs, which are included on the switch contactor and neutral block assembly. Connect the utility, generator, neutral and load cables to the terminals, which are clearly marked on the transfer switch (see Figure 5). Verify that all connections are correct before tightening lugs. All power cable lug connections must be tightened to the proper torque values as shown in Table 1 and Table 2.



WARNING



Low-voltage wire cannot be installed in the same conduit as power voltage wiring. It could result in shock due to short circuit as well as cause electromagnetic interference resulting in non-operation of the system.




Figure 4 – Power Cable Connection Locations



WARNING



Always install the transparent protective shields covering the power connections of the switch mechanism once the proper connections are performed.

LUG TORQUE VALUES

Table 1: 100A Lug Torque Values

AWG or Circular Mill Size	Tightening Torque	
	Screw Driver	External Drive Wrench
14	35	75
12	35	75
10	35	75
8	40	75
6	45	110
4	45	110
2	50	150
1	50	150
1/0	50	180

Wire size range 1/0-14 AWG copper, 1/0-12 AWG aluminum using IIsco lug # CA5-SP

Table 2: 200A Lug Torque Values

Internal Socket Size Across Flats	Tightening Torque
5/16 in. (7.93 mm)	275 in-lb (31 N·m)

Wire size range 250 kcmil-6 AWG copper or aluminum using IIsco lug # CA6-RP

SUITABLE CIRCUIT BREAKERS

Table 3: 100A Suitable Circuit Breakers

Cat. No.	Manf.	Electrical Ratings
HED4	Siemens	125 A, 240 V, 100 KA
QCHW	CH	125 A, 240 V, 22 KA
FDC	CH	150 A, 240 V, 200 KA
ED4, ED6	Siemens	125 A, 240 V, 65 KA
HED4, HED6	Siemens	125 A, 240 V, 100 KA
CED6	Siemens	125 A, 240 V, 200 KA

Table 4: 200A Suitable Circuit Breakers

Cat. No.	Manf.	Electrical Ratings
SF	GE	250 A, 240 V, 65 KA
JDB, JD	CH	225-250 A, 240 V, 65 KA
HJD	CH	225-250 A, 240 V, 100 KA
JDC	CH	250 A, 240 V, 200 KA
DK, KD, KDB	CH	400 A, 240 V, 65 KA
HKD	CH	400 A, 240 V, 100 KA
KDC, LCL, LA	CH	400 A, 240 V, 200 KA
KI	Square D	250 A, 240 V, 200 KA
LE, LX	Square D	400 A, 240 V, 100 KA
LXI	Square D	400 A, 240 V, 200 KA
FD6-A, FXD6-A	Siemens	250 A, 240 V, 65 KA
HFD6	Siemens	250 A, 240 V, 100 KA
CFD6	Siemens	250 A, 240 V, 200 KA
SFL, SFP	GE	250 A, 240 V, 100 KA

INSTALLATION AND WIRING

CONNECTIONS




Figure 5



Figure 6

NOTE: The transfer switch consists of the 6-position terminal block (shown in Figure 6) for connections.

Battery + and **Battery -** must be connected for operation of the VTSC100 controller. The battery is either 12V DC or 24V DC. A 1A fuse should be placed on the Battery + connection. Do not use an isolated power supply to power the controller as the controller requires a reference to neutral for AC sensing, which it obtains from the distribution system via Battery -.

RSC1 and **RSC2** need to be connected to the remote start/stop connections of the generator to allow automatic starting. These are N.O. dry contacts.

An optional customer-supplied test switch may be installed by the customer using the **TEST 1** and **TEST 2** terminals. A closed circuit between the test connections will simulate a utility failure. See wiring diagram for details.

The battery charger needs to be of high quality. Low-quality battery chargers will often go into full recharge mode due to VTS2 controller current draw. This will quickly wear out the battery.

VIGILANT SERIES GENERAL OPERATION

The Vigilant switch in combination with the VTSC100 timing module will allow for the automatic transfer of an electrical load to a standby power source in the event of an over/under voltage or frequency condition on any or all phases of the utility power supply.

In the event of an over/under voltage or frequency condition of utility power, the onboard VTSC100 sensing circuitry will begin the initiation of the transfer process. Upon initial sensing of a loss of utility power, the Vigilant transfer switch is specifically designed to allow an engine start time delay period (TDES) to expire before starting the generator. This engine start time delay is user-adjustable from the VTSC100, preventing unnecessary engine starts from a temporary loss of utility. In the event the utility source is not restored after the engine start time delay has expired, the remote contacts will close, sending a signal to the generator's automatic start controller.

When the VTSC100 senses that the generator has started, and is within acceptable limits, the transfer switch will wait until the utility to generator time delay (TDNE) has expired before switching to the generator position. All connected loads will be transferred to the generator power source.

While the transfer switch is in the generator position, the VTSC100 will constantly monitor the utility source voltage and frequency status. Once the utility source is restored, the transfer switch will wait until the generator to utility time delay (TDEN) has expired before switching back to the utility position. All connected loads are transferred to the utility power source.

When connected loads are transferred back to the utility power source, an engine cooldown period (TDEC) will be initiated, allowing the generator to run in a no-load condition. This engine cooldown time delay is user-adjustable from the VTSC100, allowing the generator to continue running for an adjustable period after the utility is restored.

ADJUSTMENTS AND SETTINGS

VIGILANT SERIES ADJUSTMENTS AND SETTINGS

The Vigilant series adjustments and settings may be made from the onboard VTSC100 transfer switch controller. The general settings and adjustments are as follows. See the VTSC100 controller user manual for detailed information on adjustments.



DANGER



Never adjust settings on the transfer switch controller while the controller is energized. Always completely isolate all power sources from the controller and transfer switch mechanism before making any adjustments.




Figure 7

ADJUSTMENTS AND SETTINGS

System Adjustments




Table 5: Dip Switch Settings

Feature		Switch Settings															
		Set	Function	Set	Function	Set	Function	Set	Function	Set	Function	Set	Function	Set	Function	Set	Function
1	Set the unit for 120/240V or 277/480V AC systems	ON	120/240	OFF	277/480	–		–		–		–		–		–	
2*	Set the unit for 50/60Hz systems	ON	60 Hz	OFF	50 Hz	–		–		–		–		–		–	
3*	Weekly exercise with load/no load	ON	Load test cycle	OFF	No load test cycle	–		–		–		–		–		–	
4	Set the over/under voltage setting	OFF	Dropout v 18% Pickup v 13%	OFF	Dropout v 17% Pickup v 12%	OFF	Dropout v 16% Pickup v 11%	OFF	Dropout v 15% Pickup v 10%	ON	Dropout v 14% Pickup v 9%	ON	Dropout v 13% Pickup v 8%	ON	Dropout v 12% Pickup v 7%	ON	Dropout v 11% Pickup v 6%
5		OFF		OFF		ON		ON		OFF		OFF		ON		ON	
6		OFF		ON		OFF		ON		OFF		ON		OFF		ON	
7	Set the over/under frequency setting	OFF	12%	OFF	11%	OFF	10%	OFF	9%	ON	8%	ON	7%	ON	6%	ON	5%
8		OFF		OFF		ON		ON		OFF		OFF		ON		ON	
9		OFF		ON		OFF		ON		OFF		ON		OFF		ON	

ADJUSTMENTS AND SETTINGS

Timing Adjustments




Figure 8

Table 6:

POT ID	Description
TDEC	Time Delay Engine Cool: This delay allows the engine to continue running after the transfer switch returns to the normal (utility) position. When the VTSC100 recognizes that the transfer switch is in the normal (utility) position after an emergency generator to normal (utility) transfer, the generator will continue to run under a no-load condition until the engine cool time delay has expired.
TDES	Time Delay Engine Start: This delay prevents unnecessary engine starts. When the VTSC100 determines a utility failure, it will wait for the Engine start time delay to expire before trying to start the generator
TDNE	Time Delay Normal (utility) to Emergency (Generator): This delay allows the generator to stabilize before any load is transferred. This normal (utility) to emergency (generator) time delay allows the generator to be fully running before supplying power to a load.
TDEN	Time Delay Emergency (Generator) to Normal (utility): This delay allows the utility source to be monitored for stability. This emergency (generator) to normal (utility) time delay allows the utility to be monitored for the set amount of time to confirm that it is fully restored and stable


Testing Adjustments

Controller test switch



Manual testing of the Vigilant transfer switches may be achieved by manual adjustment of the test switch located on the VTSC100. The controller test switch will allow manual testing of the transfer switch. The purpose of the test switch is to simulate a utility power failure. Normally the test switch would be set to the utility position, allowing proper sensing for normal utility faults. To simulate a utility fault when no fault actually exists, the test switch would be set to the test position, allowing the transfer switch to transfer to the generator position. After testing, utility power can be restored simply by setting the test switch back to the utility position.

Remote test switch



The remote test switch will allow remote testing of the transfer switch. The purpose of the test switch is to simulate a utility power failure. The remote test switch may be installed by a licensed electrical contractor; the switch would be installed at the TEST 1 and TEST 2 on the terminal block. Normally the test switch would be set to the DISABLE position, allowing proper sensing for normal utility faults. To simulate a utility fault when no fault actually exists, the test switch would be set to the ENABLE position, allowing the transfer switch to transfer to the generator position. A SPST test switch rated at a minimum of 1A should be used.

Exerciser



The purpose of the exerciser is to perform a test of the transfer switch either manually or automatically. The exerciser may be adjusted by a licensed electrical contractor to any specific time or day in which to perform a test. The exerciser can perform a test for a load or no-load condition. For details instructions on operational and setting instructions, see *ENGINE EXERCISER AND EXTERNAL LED ANNUNCIATION* on page 26.

MANUAL TRANSFER

MANUAL TRANSFER OF MECHANISM

WARNING



Never perform a manual transfer while the transfer switch is under load. Manual transfer is not recommended. If performing an emergency manual transfer, be certain to isolate the transfer switch from all power and load sources.

Manual transferring is not recommended. If the transfer switch fails to transfer in an emergency, an optional manual transfer may be performed. Caution must be taken to confirm that the transfer switch is isolated from all possible load sources before transferring. Please note the flat side of the removable handle must face away from the power connection side of the switch mechanism as seen in Figure 10 for easy transferring. Always remove the handle from the manual transfer handle lever location after each transfer.

100A/200A Manual Transfer

In 100 and 200A transfer switches, the manual transfer lever located on the contactor is used to manually transfer between the utility and generator position. With the lever facing up toward the normal side, the switch will be in the normal position. With the lever down facing toward the emergency side, the switch will be in the emergency position.

WARNING



Never allow the removable lever handle to come in contact with live wires or terminals.



Figure 9 – Removable Lever Handle




Figure 10 – Manual Transfer Lever Location

RECOMMENDED MAINTENANCE



WARNING



Always isolate the transfer switch from all possible power sources when performing maintenance on the mechanism.

Periodically inspect all terminals (load, line and control) and all fasteners for any loose parts or wiring.

Periodically inspect all terminals (load, line and control) and all fasteners for tightness.

Test the transfer switch operation upon initial installation. Periodically check for any excessive wear on any mechanical operating parts or wiring connections. Clean or replace parts when necessary.

All transfer switch parts are made of corrosion-resistant material or are plated, coated or painted for corrosion protection.

Table 7:

Procedure	Action
Make the transfer switch safe for inspection and maintenance	Disconnect all possible power sources before switch inspection.
Inspect the transfer switch location for possible safety hazards	Inspect mounting location for any safety or fire hazards. Inspect for dirt, wiring damage and mechanical damage.
Inspect the transfer switch for loose hardware	Check all hardware including controller, exerciser, terminals, etc. for any looseness due to vibrations, etc.
Check for any overheating due to loose connections	Check for any discoloration, melting or blistering of wiring or connections.
Perform regular testing of the transfer switch	Perform regular testing of the switch to check for proper operation in case of emergency.

MAINTENANCE

Always maintain a 3 feet (92 cm) clearance around the Vigilant transfer switch. Once a month, visually inspect the outside of the switch for accumulation of dirt, moisture and/or corrosion on the enclosure.


The homeowner or end user is responsible for following all maintenance and periodic testing procedures and guidelines of the generator owner's manual to ensure proper operation.

Once a year, have a licensed electrician clean the inside of the switch and inspect for:


- Damage or loose parts
- Discoloration of wire insulation or components




MGVATS2001240 GENERAL ARRANGEMENT



MGVATS2001240 GENERAL ARRANGEMENT 2



MGVATS1001240/MAGVATS2001240 WIRING DIAGRAM



EXERCISER

ENGINE EXERCISER AND EXTERNAL LED ANNUNCIATION

Introduction

All Vigilant series transfer switches include an external engine exerciser and LED annunciation. The engine exerciser is easily adjustable from outside the transfer switch enclosure. External LED indication is included on all Vigilant series switches, allowing visual controller status. The user may set the engine exerciser to simulate a utility power failure and test the functionality of the transfer switch system. The exact day and time may be specified for testing. External LED indication is available for utility available, generator NEMA 3 available, transfer to utility, transfer to generator and exercise/test run. Illumination is explained in detail in the VTSC100 user manual. The functions of the exerciser time clock are listed below. The exercise time clock is used to set specific times to test the transfer switch operation. The RESET button initializes the time clock, erasing any previous program. The following sections will explain how to:

1. Set current time and date
2. Set program timing
3. Review your program
4. ON/AUTO/OFF mode



Figure 11




Figure 12 – NEMA 3




Figure 13

NOTE: The exerciser clock has a backup battery. The clock runs off the battery when utility power is not available. The battery is not rechargeable.

Clearing the Exerciser

Clear the timer before continuing. To do this, press the round button just above the MIN button.

Set Current Time and Date

1. Press CLOCK and DAY buttons until the current day shows. Release both buttons for current day setting.
2. Press CLOCK and HOUR buttons until the current hour shows. Release both buttons for current hour setting.
3. Press CLOCK and MIN buttons until the current minute shows. Release both buttons for current minute setting.

Set Program Timing

1. Press the TIMER button on the exerciser clock. The "1ON" will appear at the left side of the display. The "1ON" represents when the testing start will begin.
2. Press the DAY button to select the program day period. There are 15 possible choices to choose from, which can be selected by repeatedly pressing the DAY button. The 15 possible selections are:

- | | | |
|--------------|----------------|-------------------|
| 1. Mo. to Su | 6. Fr. | 11. Mo. to Sa. |
| 2. Mo. | 7. Sa. | 12. Mo. to We. |
| 3. Tu. | 8. Su. | 13. Th. to Sa. |
| 4. We. | 9. Mo. to Fr. | 14. Mo., We., Fr. |
| 5. Th. | 10. Sa. to Su. | 15. Tu., Th., Sa. |

3. Press the HOUR button to set the hour.
4. Press the MIN button to set the minute.
5. After setting the above testing start time, press the TIMER button. After the TIMER button is pressed, the "1OFF" will appear at the left side of the display. Selection must match the "1ON" setting. The "1OFF" represents when the testing will end.
6. Repeat steps 2, 3 and 4 to set the time when the system test is to end.
7. Press the CLOCK button to start the exerciser clock.

NOTE: Unused ON and OFF times must have dashes, not zeros. The time of day is displayed in the 24-hour notation, so 00:00 is midnight.

Program Review

1. Repeatedly press TIMER button to advance the display to each subsequent ON or OFF user setting.
2. The user-set days and times will be displayed.
3. To make a change in a specific setting, repeat *Set Program Timing* on page 27.

ON/AUTO/OFF Mode

1. The ON/AUTO/OFF mode may be selected by pressing the manual button.
2. When the ON mode is selected, the transfer switch will go directly to the test mode. The test mode will stay active until the ON mode is not selected.
3. When the AUTO mode is selected, the timer will monitor the user-settable program times. The transfer switch will be tested using the programmed start and end times.

NOTE: Go to the OFF mode first, and then back to the AUTO mode when coming from the ON mode. The generator will continue to run if AUTO is selected directly from Run.

4. When the OFF mode is selected, the timer will not monitor any user-settable program times. The exerciser will not signal to start the generator when it is in the OFF mode.

When the transfer switch is not connected to an energized utility source, the exerciser timer will use an internal battery for memory storage. With the exerciser in the OFF position, very little current draw is required. With the exerciser in the ON position, a larger current draw is required. With the exerciser in the AUTO position, very little current draw is required when the program is not initiated. See *Table 3* for internal battery current draw:

Table 8:

Exerciser Position	Current Draw
ON	80 uA/hour
OFF	5 uA/hour
AUTO (program not initiated)	5 uA/hour
AUTO (program initiated)	80 uA/hour

The internal battery current draw would not be applicable when an energized utility source is supplying power to the switch.

WARRANTY

MILBANK MANUFACTURING VIGILANT™ OWNER WARRANTY POLICY

LIMITED WARRANTY

Milbank Manufacturing will repair or replace, free of charge, any part(s) of the equipment that is defective in material or workmanship or both providing that installation of the equipment complies with all applicable codes, industry standards, laws, regulations and provided installation manual. Milbank's Vigilant™ and associated components shall be installed only by a licensed electrical contractor, and otherwise this warranty is void. This warranty is effective for the time period and subject to the conditions stated below. For warranty service, please call Milbank Manufacturing at 888-483-5314 or Milbank's PowerGen office at (816) 410-7346 (PGTS@milbankworks.com)

THERE ARE NO OTHER EXPRESS WARRANTIES OR IMPLIED WARRANTIES, INCLUDING THOSE OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. THE ABOVE WARRANTY IS LIMITED TO THREE YEARS FROM PURCHASE. ANY AND ALL IMPLIED WARRANTIES ARE EXCLUDED AND LIABILITY FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES ARE EXCLUDED TO THE EXTENT EXCLUSION IS PERMITTED BY LAW. BUYER'S SOLE REMEDY IS THE LIMITED WARRANTY STATED ABOVE.

This warranty only applies to units sold for use in the United States of America and Canada.

WARRANTY PERIOD

Consumer Use: 5 years

Commercial Use: 5 years

The warranty period begins on the date of purchase by the first retail consumer and continues for the period of time stated above. Equipment used for primary power in place of utility is not applicable to this warranty.

WARRANTY REGISTRATION PROCESS

Thank you for choosing Milbank's Vigilant™ Series Automatic Transfer Switch for your generator system!

1. For the fastest and most efficient way to register your Vigilant™ warranty, please complete the online form at milbankworks.com/warranty (preferred method). Otherwise, please complete the postcard and return via mail.
2. Complete the online form or return the postcard within 10 days of installation.
3. Save the proof of purchase. If the Vigilant™ is not registered within 10 days, the warranty start date will default to the date of purchase by the first retail consumer.
4. If the warranty registration steps are not completed, the warranty start date will default to the manufacturing date.

ABOUT OUR WARRANTY

Any authorized service dealer may perform warranty repairs. Most warranty repairs are handled routinely, but sometimes requests for warranty service may not be appropriate or applicable. For example, warranty service would not apply if equipment damage occurred because of misuse, lack of routine maintenance, shipping, handling, warehousing, or improper installation. Similarly, the warranty is void if the manufacturing date or the serial number on the equipment has been removed, altered, or modified. During the warranty period defined above, the authorized certified technician, at its option, will repair or replace any part that, upon examination, is found to be defective under normal use and service. No allowances shall be made to the Buyer for any transportation, duties, brokerage fees, labor costs, or parts adjustments or repairs, or any other work, unless said charges have been authorized in writing, in advance, by the Seller. The Seller shall not be liable for determining whether any Article(s) or parts thereof are suitable for the Buyer's or any third-party's intended use or application. The Seller shall in no event be liable for any special or consequential damages or for loss of profit as a result of a breach of this warranty, including without limitation, any damages relating to any direct or indirect damage to property resulting from any use, removal or installation of the article(s) by the Buyer or any third-party.

This warranty will not cover the following repairs and equipment:

- **Normal Wear:** Electrical equipment, like any mechanical device, needs periodic parts and service to perform well. This warranty does not cover repair when normal use has exhausted the life of the part or equipment.
- **Installation and Maintenance:** This warranty does not apply to equipment or parts that have been subjected to improper or unauthorized installation or alteration or modification, misuse, negligence, accident, overloading, improper maintenance, repair or storage so as, in our judgment, to adversely affect its performance and reliability. This warranty also does not cover normal maintenance such as adjustments, cleaning and fuse replacement.

Other exclusions: This warranty excludes wear items or damage or malfunctions resulting from accidents, abuse, modifications, alterations, or improper servicing. Accessory parts are excluded from the product warranty. This warranty excludes failure due to acts of God and other force majeure events beyond the manufacturer's control. Also excluded is used, reconditioned, and demonstration equipment. The warranty shall not apply to any materials or parts thereof furnished by the Buyer, or acquired from others at the Buyer's request and/or the Buyer's specifications or designs.

THIS PAGE INTENTIONALLY LEFT BLANK

THIS PAGE INTENTIONALLY LEFT BLANK



MILBANK®
ENERGY AT WORK

VIGILANT™
AUTOMATIC TRANSFER SWITCH