

APPROVED CIRCUIT BREAKERS

TRANSFER PANEL MODELS: Q SERIES

SIEMENS: TYPES QP

SQUARE D: SERIES HOM

EATON/CUTLER-HAMMER: SERIES BR

MURRAY: TYPE MP

THE Q SERIES PRODUCT IS UL APPROVED FOR USE WITH THE ABOVE FIELD-INSTALLED BREAKERS.

30 AMPS MAXIMUM IN POSITIONS A AND B, 20 AMPS MAXIMUM IN ALL OTHER POSITIONS.

**RATING OF A TRANSFER SWITCH CIRCUIT BREAKER SHOULD NOT EXCEED THE RATING OF THE CORRESPONDING BRANCH CIRCUIT BREAKER IN THE LOAD CENTER.

**DO NOT INSTALL ANY BREAKER LARGER THEN 20 AMPS, EXCEPT IN POSITIONS A AND B WHICH MAY BE 30 AMPS.

**ALL CIRCUIT BREAKER POSITIONS WILL ACCOMMODATE 15 AND 20 AMP CIRCUIT BREAKERS, AND MAY BE EASILY CHANGED IN THE FIELD.