



ComfortPro Systems, LLC

8150 N. Lehigh

Morton Grove, IL 60053

Phone (800) 968-8905

Fax: (847) 967-1482

LIMITED WARRANTY

10 YEAR WARRANTY

For our ComfortPro Systems™ cross linked PEX pipe, we render the following warranty over and about our terms of Delivery: Our Cross linked pipe is manufactured from high quality, high heat stabilized Polyethylene. Within A period of 10 years from date of manufacture, we offer compensation up to a limit of 5,000,000 US dollars In individual cases and up to a limit of 5,000,000 US dollars in the whole number of cases per year, covered by a production liability insurance.

- a) for damage to property of third persons and the resulting damage therefrom, and / or
- b) for expenses to third persons for removal, dismantling, or uncovering defective products and for installing, fixing, and laying of new products to be supplied by us.
- c) furthermore we guarantee compensation for a period not exceeding 10 years after liquidation.
- d) For a period of 10 years from the date of manufacture, free replacement for the cross linked PEX pipe supplied by us in which defects arise, that can be proved to have arisen from manufacturing or material faults for which the manufacturer is responsible. This is subject to compliance with the guidelines as outlined in our installation manual.

EXTENDED 15 YEAR LIMITED WARRANTY

Limited Warranty: This limited warranty shall expire twenty-five (25) years after the date of manufacture for Our ComfortPro Systems™ cross linked PEX pipes.

ComfortPro Systems™ sole obligation hereunder shall be, at its option, to issue credit, repair or replace any article or part thereof which is proved to be other than as warranted. Further, no allowances shall be made to buyer for Transportation, labour charges or part adjustments or repair or any other work.

Additionally, any performance by buyer or its designee, of any repairs without the express written consent of ComfortPro Systems™, shall render this Warranty invalid.

GENERAL GUIDELINES FOR THE LAYING OF PEX PIPE:

1. The minimum bending radius is 6 times pipe diameter at an ambient temperature of +20°C, and 8 times pipe diameter by lower temperatures down to 0°C.
2. Fixing of the pipe must be made with suitable pipe clamps. Fixing with binding wire is not permissible.
3. Before enclosure of the PEX pipe, the pipe must be put under pressure by water or air, (if necessary antifreeze should be added). This test should be carried out at a pressure not less than 550kPa (80psi) and not more than 690kPa (100 psi) and remain thus for 24 hours, after which all connections should be tightened. The pipe is to remain under pressure while covering is being laid.
4. Storage of the PEX pipes which allows an exposure to sun light is not permissible (danger of UV rays).
5. In Areas liable to frost ComfortPro Systems™ anti-freeze is to be used.
6. Kinking and buckling points are to be removed.

NO LIABILITY CAN BE ACCEPTED FOR FAULTS IN INSTALLATION OR LAYING OF THE PIPE. OUR GENERAL LAYING DIRECTIONS ARE A CONSTITUENT PART OF THIS WARRANTY. QUALITY CONTROL CHECKS ARE CARRIED OUT UNDER CONTRACT WITH THE MANUFACTURER. COMFORTPRO SYSTEMS™ DISCLAIMS ANY EXPRESS WARRANTY NOT PROVIDED HEREIN, INCLUDING ANY IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. COMFORTPRO SYSTEMS™ FURTHER DISCLAIMS ANY RESPONSIBILITY FOR LOSSES, EXPENSES, INCONVENIENCES, SPECIAL, INDIRECT, SECONDARY INCIDENTAL OR CONSEQUENTIAL DAMAGES ARISING FROM OWNERSHIP OR USE OF THE ARTICLES SOLD HEREUNDER. THERE ARE NO WARRANTIES WHICH EXTEND BEYOND THE FACE HEREOF.