



Certificate of Compliance

Certificate: 80044568

Master Contract: 153579

Project: 80044568

Date Issued: 2020-07-09

Issued To: Pentair Flow & Filtration Solutions
293 South Wright St
Pump Division
Delavan, Wisconsin, 53115
United States

Attention: Kris Douglas

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: *Thao Cao*
Thao Cao



PRODUCTS

CLASS - C481213 - SIGNAL APPLIANCES Signal Systems

CLASS - C481285 - SIGNAL APPLIANCES Signaling Systems - Certified to US Standards

Smart Sump Pump Controller SSPC

Rated 115 Vac, 60Hz, 15A (FLA) and 35(LRA). Ambient 40°C

Note:

1. The Smart Sump Pump Controller SSPC designed not for safety application and it's only for monitoring & notification purpose.
2. Device model comes with Pseudo Plug that can be plug into back of the piggyback switch



Certificate: 80044568
Project: 80044568

Master Contract: 153579
Date Issued: 2020-07-09

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 205-17 - Signal Equipment

ANSI/UL 916 5th Edition - Energy Management System



Supplement to Certificate of Compliance

Certificate: 80044568

Master Contract: 153579

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80044568	2020-07-09	Original Certification Smart Sump Pump Controller SSPC.